

PWSID:	NJ1918351	Water System Type:	Nontransient noncommunity (NTNC)
Water System Name:	SUSSEX CTY CHARTER SCHOOL - A	System Status:	A

Lead/Copper Results for Compliance Period: 01/01/2018--12/31/2020

Lead						Copper					
5 Samples; 90th %ile: 0.0061 MG/L						5 Samples; 90th %ile: 0.373 MG/L					
Collection Date	Sample Pt ID	Sample #^	Result*	Analysis Date	Date Received	Collection Date	Sample Pt ID	Sample #^	Result*	Analysis Date	Date Received
07/16/2020	DS	20061847-001	2.98 UG/L	07/27/2020	08/06/2020	07/16/2020	DS	20061847-001	0.26 MG/L	08/03/2020	08/06/2020
07/16/2020	DS	20061847-002	6.42 UG/L	07/27/2020	08/06/2020	07/16/2020	DS	20061847-002	0.372 MG/L	08/03/2020	08/06/2020
07/16/2020	DS	20061847-003	5.8 UG/L	07/27/2020	08/06/2020	07/16/2020	DS	20061847-003	0.373 MG/L	08/03/2020	08/06/2020
07/16/2020	DS	20061847-004	<2 UG/L	07/27/2020	08/06/2020	07/16/2020	DS	20061847-004	0.33 MG/L	08/03/2020	08/06/2020
07/16/2020	DS	20061847-005	3.99 UG/L	07/27/2020	08/06/2020	07/16/2020	DS	20061847-005	0.326 MG/L	08/03/2020	08/06/2020

^Rollover sample # to see lab name and ID and METHOD

*MG/L=milligrams of contaminant per liter of water, equivalent to ppm (parts per million).
 µg/L=micrograms of contaminant per liter of water, equivalent to ppb (parts per billion).
 pCi/L=picocuries of contaminant per liter of water--a curie is a measurement of the rate at which a radioactive material decays.
 "<" (less than) means the contaminant cannot be accurately detected below the limit specified; the result can be considered zero.